

2019 Water Quality Report for City of Gladwin

Water Supply Serial Number: 02650

This report covers the drinking water quality for the city of Gladwin for the 2019 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2019. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from 3 groundwater wells, each over 600 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is well #3 –high well #4-low and well #5-low.

If you would like to know more about this report, please contact: Joe Zeitz, City DPW, 201 S State, 989-426-6943.


Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).

Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled

water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2019 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2019. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- N/A: Not applicable
- ND: not detectable at testing limit
- ppb: parts per billion or micrograms per liter
- ppm: parts per million or milligrams per liter
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	.003	NA	2012	no	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0	NA	2020	no	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	nd		2019	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	.57	.55-.59	2019	no	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium ¹ (ppm)	N/A	N/A	74	48-99	2019	no	Erosion of natural deposits
THM Total Trihalomethanes (ppb)	80	N/A	nd		2019	no	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	nd		2019	no	Byproduct of drinking water disinfection
Chlorine ² (ppm)	4	4	.8	.7-.9	2019	no	Water additive used to control microbes
Alpha emitters (pCi/L)	15	0	4.6	NA	2015	no	Erosion of natural deposits
Combined radium (pCi/L)	5	0	1	1.0-1.0	2014	no	Erosion of natural deposits
Total Coliform (total number or % of positive samples/month)	TT	N/A	0	N/A	2019	No	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli notes ³	0	0	N/A	2019	No	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A	0	N/A	2019	no	Human and animal fecal waste
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water ⁴	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	1ppb	0 ppb-3 ppb	2019	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	.59 ppm	0 ppm-.7ppm	2019	0	Corrosion of household plumbing systems; Erosion of natural deposits

Our water supply has 0 lead service lines and approximately 15 service lines of unknown material out of a total of approximately 1150 service lines.

Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements:
The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety.

During the monitoring period from JULY 1-2019 to December 31-2019 we did not take and have analyzed, the required water quality parameter samples for ;alkalinity, pH, chloride, sulfate, and orthophosphate, as set forth by state guide line which resulted in a violation. These samples were to be taken at the sample point in the distribution system. They were erroneously taken at the wells themselves. This violation did not pose a threat to the quality of the drinking water. Corrective measures have been taken.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at city hall 1000 w Cedar Ave.

We invite public participation in decisions that affect drinking water quality. Please feel free to attend any of our regularly scheduled council meetings. They are held on the first and third Mondays of the month at 5:00pm at city hall 1000 W Cedar Ave For more information about your water, or the contents of this report, contact Joe Zeitz 989-426-6943. For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.